



Republic of the Philippines
DEPARTMENT OF HEALTH
PHILIPPINE CHILDREN'S MEDICAL CENTER

Quezon Avenue, Quezon City 1100

website: www.pcmc.gov.ph email: officeofthedirector@pcmc.gov.ph

Trunkline: 588-9900 DirectLine: 924-0836 Fax No: 924-0840

BID BULLETIN NO. BB-2021-032

Date : 05/24/2021
 To : ALL PROSPECTIVE BIDDERS
 From : BIDS AND AWARDS COMMITTEE
 Subject : AMENDMENT / CLARIFICATION AS STATED
 Name of Project : IB-2021-066 : One (1) Lot Renovation of PCMC's Old Building (Phase 2)
 (ABC = Php 339,803,811.00)

This Bid Bulletin No. BB-2021-032 outlines the amendments/clarifications on the following which shall form an integral part of the Bidding Documents:

AMENDMENT :


PARTICULAR	FROM	TO
Section III. BID DATA SHEET 10.3 Valid Philippine Contractor's Accreditation Board (PCAB) License and registration:	<ul style="list-style-type: none"> • License Category AAA, Large B, General Building In case of Joint Venture a Special PCAB License License Category AAA, Large B, General Building •Special PCAB License for the following: Fire Protection Small B License Category C and D 	<ul style="list-style-type: none"> • License Category AAA, Large B, General Building In case of Joint Venture a Special PCAB License License Category AAA, Large B, General Building
10.4 The key personnel must meet the required minimum years of experience set below: Key Personnel : Minimum Years of relevant Experience	Project-in-Charge - (Registered Civil) 5 years	Project-in-Charge - (Registered Civil or Architect) 10 years
Section V. SPECIAL CONDITIONS OF CONTRACT 11.1 The Contractor shall submit the Program of Work to the Procuring Entity's Representative within	Fourteen (14) days of delivery of the Notice of Award.	Fourteen (14) days from receipt of the Notice of Proceed.
DETAILED ESTIMATE FORM	Format with GRAND TOTAL	Use attached revised format (Grand Total portion - deleted)

BID BULLETIN NO. BB-2021-032

CLARIFICATION :

QUERY	RESPONSE
In the Powerpoint presentation on preparation of BOQ, there's a column for Equipment Cost. But in the E-file of the BOQ, there's none. In this case, which will prevail?	The E-file of the Bill of Quantities will prevail.
Under hauling and disposal of debris, the owner will provide disposal site or the contractor will designate?	PCMC will designate the <u>temporary</u> disposal site within the PCMC campus. The Contractor is responsible in disposing the debris outside the PCMC grounds.
What is the thickness of the glass roof for Lanai?	Thickness of the structural glass roof for Lanai is 12mm tempered.

For information and guidance of all concerned.


MARIA ROSARIO S. CRUZ, M.D.
Chairperson, BAC