



PHILIPPINE CHILDREN'S MEDICAL CENTER
 Quezon Avenue, Quezon City
 Tel. No. 8588-9900 local 224/226

REQUEST FOR QUOTATION
 No. RFQ-2020-475

Date : _____
 Name of Supplier : _____
 Address : _____
 Telephone No. : _____

Please quote your lowest price as per specifications per item listed below thru :

Alternative Mode of Procurement - (Negotiated Procurement : RA No. 11494, Bayanihan Act 2) on or before **December 7, 2020**

PhilGEPS Reference No. _____ posted on _____.

Please fax your quotation at **8588-9997** or email at pcmcproc@gmail.com

PCMC REQUIREMENT			OFFER TO COMPLY WITH THE REQUIREMENTS			
Item No.	QTY	UNIT				
1	5	UNIT	AIRBORNE PURIFICATION HEPA FILTRATION SYSTEM	BRAND:		
				MAKE/MODEL:		
			ABC per unit : 940,000.00	UNIT COST :		
			Total ABC : 4,700,000.00	TOTAL COST :		
			A. Specifications:			
			➤ 100% efficient against the following: Tuberculosis, Influenza Virus, Aspergillosis, SARS, Varicella, COVID-19			
			➤ Capable of 360 degrees uniform air extraction and supply			
			➤ Minimum requirement of airflow of 600 cubic meter per hour			
			➤ able to achieve clean air classification: ISO 5 of ISO 6 level of 0.5 microns (based in CDC Standard reference ISO14644-1 table)			
			➤ Minimum requirement of air quality result is achieved in no more than 20 minutes			
			➤ Unit Dimension: Compact size			
			➤ With stainless steel trolley if mobile or wall mounted bracket			
			➤ With at least selectable standard fan speed			
			➤ Fan stage can be adjusted to silent, basic, high and intensive levels, Capable of fan adjustment			
			➤ With at least HEPA Filter type composed of Pre-Filter, Activated Carbon Filter and HEPA filter			
			➤ 4 speed levels - silent (night level) for patients			
			➤ Complies to EN1822 standards			
			➤ Fine dust pre-filter Class F9 - SN EN 779			
			➤ Activated Carbon, non impregnated, natural product			
			➤ Minimum requirement for areas up to approx. 30 m2/ 80 m3			
➤ With LED Display monitoring indicators for filter degree contamination						
➤ With remote control						



PHILIPPINE CHILDREN'S MEDICAL CENTER
 Quezon Avenue, Quezon City
 Tel. No. 8588-9900 local 224/226

REQUEST FOR QUOTATION
No. RFQ-2020-475

➤	With wall bracket system and can be wall mounted and can be table top	
➤	Anti bacterial casing with White powder coated steel at least 1.0mm	
➤	Minimum requirement of weight of not more than 16 kilograms	
➤	230V, 60Hz, 80 Watts	
➤	Complies with CE standard	
➤	Validation & Certification of HEPA Filter efficiency	
➤		
	Other Specifications: (please indicate if applicable)	
➤		
	BRAND:	
	MAKE/MODEL:	
	B. Accessories Per Unit:	
➤		
➤		
	D. Warranty:	
➤	At least 2 year on parts and labor	
➤	With quarterly Preventive Maintenance and Particle Counting for verification of the Air quality of the area	
	E. Requirement Delivery Period:	
	30 to 45 calendar days	

PCMC has the right to reject any or all bids without offering any reason, waive any required formality and award the contract to any bidder whose proposals as evaluated by PCMC is the most advantageous to the government.

Please attached Brochure

Documentary Requirements

- Mayor's/Business Permit
- PhilGEPS Reg. Number
- Income / Business Tax Return (For ABC's above Php500,000.00)
- Omnibus Sworn Statement (For ABC's above Php50,000.00) [Use of the Form provided is required]

Posting of Warranty Security:

The obligation for the warranty shall be covered by retention money in an amount equivalent to at least five percent (5%) of the Contract Price deductible to final payment.

The said amount shall only be released after the lapse of the warranty period specified above; provided, however, that the Supplies delivered are free from patent and latent defects and all the conditions imposed under this Contract have been fully met.

 Signature over Printed Name

HSPR-PCMC-RQF3
 170314 Rev 1

**For Certificate of Creditable Tax Withheld at Source (BIR Form N. 2307) and Certificate of Final Tax Withheld at Source (BIR Form No. 2306) please submit your latest/updated BIR Certificate of Registration together with your quote.*

12/2/20