



PHILIPPINE CHILDREN'S MEDICAL CENTER
 Quezon Avenue, Quezon City
 Tel. No. 8588-9900 local 224/226

REQUEST FOR QUOTATION
 No. RFQ-2020-484

Date : _____
 Name of Supplier : _____
 Address : _____
 Telephone No. : _____

Please quote your lowest price as per specifications per item listed below thru :
 Alternative Mode of Procurement - (Negotiated Procurement-RA No. 11494, Bayanihan Act 2) on or before **December 7, 2020**
 PhilGEPS Reference No. _____ posted on _____
 Please fax your quotation at **8588-9997** or email at **pcmcproc@gmail.com**

PCMC REQUIREMENT				OFFER TO COMPLY WITH THE REQUIREMENTS
Item No.	QTY	UNIT	Item Description	
1	1	LOT	SUPPLY, DELIVERY, INSTALLATION, TESTING AND COMMISSIONING	BRAND:
				MAKE/MODEL:
				UNIT COST :
				TOTAL COST :
1	1	LOT	Complete Facility Negative Pressure System of all areas of Covid Isolation Rooms compliance to DOH Guidelines 2020-0062 Airborne Infection Isolation Room Standards	
			ABC per unit : 8,725,074.14	
2	1	LOT	Complete Facility Negative Pressure System of all areas of Emergency Room compliance to DOH Guidelines 2020-0062 Airborne Infection Isolation Room Standards	
			ABC per unit : 8,869,177.74	
3	2	LOT	Complete Facility Negative Pressure System of one (1) Isolation Room of NICU & PICU compliance to DOH Guidelines 2020-0062 Airborne Infection Isolation Room Standards	
			ABC per unit : 1,075,282.30	
			Total ABC : 2,150,564.60	
			Grand Total : 19,744,816.48	
General Specifications:				
1	Negative pressure facility shall serve a single-patient occupancy room with high exhaust pressure relative to the surroundings areas			
2	Airflow capability must be at least six (6) air changes per hour. Parameters and airflow calculations shall be submitted for verification			
3	Air exhaust should be directed away from people and air intakes. Must be filtered through a HEPA filter to meet environmental and patient safety			
4	Shall supply and install appropriate labels or signages at the door to identify a negative-pressured isolation rooms			
5	Should have pressure level control, daily monitoring system and alarm (visual/audible) system in case of pressure dropping and pressure compensation			



REQUEST FOR QUOTATION
No. RFQ-2020-484

6	Shall supply and install properly sized centralized aircondition facility for isolation rooms. Ducted airflow inlet for air-conditioning capable to maintain room temperature of 23 degrees celsius and below (relative humidity level of 50%)	
7	Complete ducting structures and exhaust facility integrated from isolation rooms directed to outside of the hospital. The discharge system must be far away from people traffic site	
8	Split type AC rectangular ducting system and calculated exhaust equipment that deliver discharge waste air thru ducting structures. Equipment duct and piping shall be supported by hangers support and metal platforms	
9	Supplier to perform necessary testing and commissioning of the system which includes but not limited to smoke test, power test, room temperature check, leak test, airflow adjustment, humidity check airchanges calibration and validation	
Other Specifications: (Please indicate if applicable)		
➤		
➤		
BRAND:		
MAKE/MODEL:		
B. Accessories Per Unit		
➤		
➤		
C. Warranty:		
➤	Two (2) years warranty, quarterly Preventive Maintenance Services and Annual Calibration Services. Free of charge emergency repairs, consumables if any and service parts during warranty period.	
D. Requirement Delivery Period:		
	30 to 45 calendar days	

PCMC has the right to reject any or all bids without offering any reason, waive any required formality and award the contract to any bidder whose proposals as evaluated by PCMC is the most advantageous to the government.

Please attached Brochure

Documentary Requirements

- Mayor's/Business Permit
- PhilGEPS Reg. Number
- Income / Business Tax Return (For ABC's above Php500,000.00)
- Omnibus Sworn Statement (For ABC's above Php50,000.00) [Use of the Form provided is required]

Posting of Warranty Security:

The obligation for the warranty shall be covered by retention money in an amount equivalent to at least five percent (5%) of the Contract Price deductible to final payment.

The said amount shall only be released after the lapse of the warranty period specified above; provided, however, that the Supplies delivered are free from patent and latent defects and all the conditions imposed under this Contract have been fully met.

rx 12/3/20

 Signature over Printed Name

HSPR-PCMC-RQF3
 170314 Rev 1